



**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**



From
The District fire officer,
Rangareddy Division.

To,
Chaitanya Bharathi Institute of Technology,
Kokapet Village,
Gandipet Mandal,
Ranga Reddy District,

Ack. No.383190002021 Dated:22/04/2021

Sir,

Sub: TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT –Rangareddy Division. Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building of Block A, B, C, D & E,CBIT/-Kokapet/Gandipet/Rangareddy , – Regarding.



Ref:

1. Acknowledgement No 383190002021
2. This Office NOC for Occupancy Ack/RC No.2251/A1/2015 dt.22/04/2021
3. Non Multi storeyed Building Inspection Committee Report, Ack. No. 383190002021, dt. 22/04/2021

- 1) The Non Multi storeyed Building Inspection committee, vide reference cited (3) has inspected the Non Multi storeyed Building of Block A, B, C, D & E,CBIT/-Kokapet/Gandipet/Rangareddy
- 2) The above said building was issued was issued No Objection certificate vide reference cited (2) for Non Multi storeyed Building with 2 Ground, 3 Floors, 1 Terrace with a height of 14.95 Meters for EDUCATIONAL B-2 All others/training institutions Occupancy .
- 3) Now the Builder/Authorized person has requested to issue Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building with 2 Ground, 3 Floors, 1 Terrace with a height of 14.95 Meters for EDUCATIONAL B-2 All others/training institutions Occupancy

4) Open Spaces:The builder provided the following open spaces all around the building.

Sl.No	Side	Open spaces as per Noc occupancy	Open spaces provided now
1	North	3.00	13.87
2	South	3.00	25.59
3	East	3.00	10.00
4	West	3.00	30.00

b.Sl. No	Gate Width As per Occupancy NOC	as per Noc occupancy	provided now
1	Entry gate width	4.50	4.5
2	Entry Gate Head Clearance	5.00	5
3	Exit Gate Width	4.50	4.5
4	Exit Gate Head Clearance	5.00	5

5) Travel Distance

Sl. No.	Item / Description	as per Noc occupancy	provided now
1	Farthest point (Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	10.00	10.00
2	The Dead end of the corridor length in exit access. (6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	6.00	6.00

6) Stair Cases (As per Occupancy NOC) :

Sl.no.	Type of staircases	Total width	No of staircases	Floors from	Floors to
--------	--------------------	-------------	------------------	-------------	-----------

1	Internal staircases	1.83	3	Ground	Terrace
2	External staircases	1.83	2	Ground	Terrace

7) Means of Escape Floor Wise Details :

Sl.no	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy	Occupant Load	Means of escape required as per Occupancy NOC	Means escape available now
1	Lower Ground	116.82	EDUCATIONAL B-2 All others/training institutions	29.00	0.58	1.83
2	Ground	3171.64	EDUCATIONAL B-2 All others/training institutions	793.00	9.15	9.15
3	1st Floor	3095.34	EDUCATIONAL B-2 All others/training institutions	774.00	9.15	9.15
4	2nd Floor	3095.34	EDUCATIONAL B-2 All others/training institutions	774.00	9.15	9.15
5	3rd Floor	1160.78	EDUCATIONAL B-2 All others/training institutions	290.00	9.15	9.15
6	Terrace	379.98	EDUCATIONAL B-2 All others/training institutions	95.00	9.15	9.15

8) Fire Shaft as per Occupancy NOC:

9) Floor Wise details of Fire Fighting Installations:

Sl.no	Floor Details	Fire Extinguisher	Hose Reel	Automatic Sprinklers System	Manually Operated Electronic Fire Alarm System	Automatic detection and alarm system
1	Lower Ground	1.00	1.00	0.00	0.00	0.00
2	Ground	16.00	4.00	0.00	0.00	0.00
3	1st Floor	16.00	4.00	0.00	0.00	0.00
4	2nd Floor	16.00	4.00	0.00	0.00	0.00
5	3rd Floor	6.00	2.00	0.00	0.00	0.00
6	Terrace	0.00	0.00	0.00	0.00	0.00

10) Fire Fighting Installations As per Occupancy NOC :

Fire Fighting System.	Required As per Occupancy NOC	Provided
Fire Extinguishers	112	112
First Aid Hose Reel	25	25
Fire Riser	1	1
Terrace Tank over Respective Tower Terrace in Litres	25000	25000
Pump Capacity in LPM at the Terrace Tank Level with Minimum Pressure of 3.5 kg/cm ²	900	900

11). The Non Multi storeyed Building Inspection Committee have reported that the Management has provided the Fire Safety Measures and there is no deficiencies.

12. Remarks :

As per the recommendation of the Inspection Committee in Sl. No.6, the issuance of Renewal of NOC for Occupancy is approved.

13) In view of the above and as per recommendations of the Non Multi storeyed building inspection Committee, the Renewal of No Objection Certificate for occupancy is issued to Non Multi storeyed Building with Block A, B, C, D & E, CBIT/-Kokapet/Gandipet/Rangareddy with a height of 14.95 Meters for EDUCATIONAL B-2 All others/training institutions Occupancy subject to the following conditions

Sl No	Builder and Management Body	Occupant	Management Body and fire and security personnel
1	-a) All the fire protection	All the escape/exit routes shall	All the occupants must know the correct

	arrangements shall be maintained in good condition as seen during inspection. -b) Do's and Don'ts in case of fire shall be prominently displayed in entire building	not be kept locked/blocked or encroached	method of operation of the fire fighting systems installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.	All occupants shall be trained to operate the fire safety equipment during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipment during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101.
4	This No objection Certificate for occupancy is valid for Five year from the date of issue of this letter.	Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing doors and windows.

This Renewal of No Objection Certificate for Occupancy is valid for Five years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison – A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.

Yours Sincerely,
District fire officer,
Rangareddy Division.

Copies to:

- i) The Management
- ii) Non Multi storeyed Building Inspection Committee
- iii) Copy submitted to Regional Fire officer
- iv) Copy submitted to DG fire services

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"



**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**



From
The District fire officer,
Rangareddy Division.

To,
Chaitanya Bharathi Institute of Technology,
Kokapet Village,
Gandipet Mandal,
Ranga Reddy District,

Ack. No.383170002021 Dated:22/04/2021



Sir,
Sub: **TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT –Rangareddy Division. Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building of Block G,CBIT/-Kokapet/Gandipet/Rangareddy , – Regarding.**

Ref: 1. Acknowledgement No 383170002021
2. This Office NOC for Occupancy Ack/RC No.2251/A1/2015 dt.22/04/2021
3. Non Multi storeyed Building Inspection Committee Report,
Ack. No. 383170002021, dt. 22/04/2021

- 1) The Non Multi storeyed Building Inspection committee, vide reference cited (3) has inspected the Non Multi storeyed Building of **Block G,CBIT/-Kokapet/Gandipet/Rangareddy**
- 2) The above said building was issued was issued No Objection certificate vide reference cited (2) for Non Multi storeyed Building with **1 Ground**, with a height of **4.57 Meters** for **EDUCATIONAL B-2 All others/training institutions** Occupancy .
- 3) Now the Builder/Authorized person has requested to issue Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building with **1 Ground**, with a height of **4.57 Meters** for **EDUCATIONAL B-2 All others/training institutions** Occupancy

4) Open Spaces:The builder provided the following open spaces all around the building.

Sl.No	Side	Open spaces as per Noc occupancy	Open spaces provided now
a 1	North	6.00	10.00
2	South	6.00	10.00
3	East	6.00	10.00
4	West	6.00	10.00
b Sl. No	Gate Width As per Occupancy NOC	as per Noc occupancy	provided now
1	Entry gate width	4.50	4.5
2	Entry Gate Head Clearance	5.00	5
3	Exit Gate Width	4.50	4.5
4	Exit Gate Head Clearance	5.00	5

5) Travel Distance

Sl. No.	Item / Description	as per Noc occupancy	provided now
1	Farthest point (Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	0.00	0.00
2	The Dead end of the corridor length in exit access. (6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	0.00	0.00

6) Stair Cases (As per Occupancy NOC) :

Sl.no.	Type of staircases	Total width	No of staircases	Floors from	Floors to
1	Ramp(Used for Movement of Vehicles)	5.50	0	Ground	Ground

7) Means of Escape Floor Wise Details :

Sl.no	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy	Occupant Load	Means of escape required as per Occupancy NOC	Means escape available now
1	Ground	1923.64	EDUCATIONAL B-2 All others/training institutions	481.00	0.00	0.00

8) Fire Shaft as per Occupancy NOC:

9) Floor Wise details of Fire Fighting Installations:

Sl.no	Floor Details	Fire Extinguisher	Hose Reel	Automatic Sprinklers System	Manually Operated Fire Alarm System	Electronic Fire Alarm System	Automatic detection and alarm system
1	Ground	10.00	2.00	0.00	0.00	0.00	0.00

10) Fire Fighting Installations As per Occupancy NOC :

Fire Fighting System.	Required As per Occupancy NOC	Provided
Fire Extinguishers	21	21

11). The Non Multi storeyed Building Inspection Committee have reported that the Management has provided the Fire Safety Measures and there is no deficiencies.

12. Remarks :

As per the recommendation of the Inspection Committee in Sl. No.3, the issuance of Renewal of NOC for Occupancy is approved.

13) In view of the above and as per recommendations of the Non Multi storeyed building inspection Committee, the Renewal of No Objection Certificate for occupancy is issued to Non Multi storeyed Building with Block G,CBIT/-Kokapet/Gandipet/Rangareddy with a height of 4.57 Meters for EDUCATIONAL B-2 All others/training institutions Occupancy subject to the following conditions

Sl No	Builder and Management Body	Occupant	Management Body and fire and security personnel
1	-a) All the fire protection arrangements shall be maintained in good condition as seen during inspection. -b) Do's and Don'ts in case of fire shall be prominently displayed in entire building	All the escape/exit roots shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting systems installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.	All occupants shall be trained to operate the fire safety equipment during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipment during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101.
4	This No objection Certificate for occupancy is valid for Five year from the date of issue of this letter.	Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing doors and windows.

This Renewal of No Objection Certificate for Occupancy is valid for Five years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison - A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.

Yours Sincerely,
District fire officer,
Rangareddy Division.

Copies to:

- i) The Management
- ii) Non Multi storeyed Building Inspection Committee
- iii) Copy submitted to Regional Fire officer
- iv) Copy submitted to DG fire services

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"



**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**



From
The District fire officer,
Rangareddy Division.

To,
Chaitanya Bharathi Institute of Technology,
Kokapet Village,
Gandipet Mandal,
Ranga Reddy District,

Ack. No.383180002021 Dated:25/04/2021



Sir,
Sub: **TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT –Rangareddy Division. Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building of Block H,CBIT/-Kokapet/Gandipet/Rangareddy , – Regarding.**

Ref: 1. Acknowledgement No 383180002021
2. This Office NOC for Occupancy Ack/RC No.2251/A1/2015 dt.25/04/2021
3. Non Multi storeyed Building Inspection Committee Report,
Ack. No. 383180002021, dt. 25/04/2021

***** ***** *****

- 1) The Non Multi storeyed Building Inspection committee, vide reference cited (3) has inspected the Non Multi storeyed Building of **Block H,CBIT/-Kokapet/Gandipet/Rangareddy**
- 2) The above said building was issued was issued No Objection certificate vide reference cited (2) for Non Multi storeyed Building with **1 Ground**, with a height of **4.57 Meters** for **EDUCATIONAL B-2 All others/training institutions** Occupancy .
- 3) Now the Builder/Authorized person has requested to issue Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building with **1 Ground**, with a height of **4.57 Meters** for **EDUCATIONAL B-2 All others/training institutions** Occupancy

4) Open Spaces:The builder provided the following open spaces all around the building.

Sl.No	Side	Open spaces as per Noc occupancy	Open spaces provided now
1	North	3.00	21.60
2	South	3.00	21.60
3	East	3.00	20.00
4	West	3.00	16.90

b Sl. No	Gate Width As per Occupancy NOC	as per Noc occupancy	provided now
1	Entry gate width	6.00	6
2	Entry Gate Head Clearance	5.00	5
3	Exit Gate Width	6.00	6
4	Exit Gate Head Clearance	5.00	5

5) Travel Distance

Sl. No.	Item / Description	as per Noc occupancy	provided now
1	Farthest point (Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	12.00	12.00
2	The Dead end of the corridor length in exit access. (6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	3.00	3.00

6) Stair Cases (As per Occupancy NOC) :

Sl.no.	Type of staircases	Total width	No of staircases	Floors from	Floors to
1	Ramp(Used for Movement of Vehicles)	0.00	0	Ground	Ground

7) Means of Escape Floor Wise Details :

Sl.no	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy	Occupant Load	Means of escape required as per Occupancy NOC	Means escape available now
1	Ground	932.34	EDUCATIONAL B-2 All others/training institutions	233.00	4.66	10.00

8) Fire Shaft as per Occupancy NOC:

9) Floor Wise details of Fire Fighting Installations:

Sl.n	Floor Details	Fire Extinguisher	Hose Reel	Automatic Sprinklers System	Manually Operated Fire Alarm System	Electronic Fire Alarm System	Automate detection and alarm system
1	Ground	10.00	0.00	0.00	0.00	0.00	0.00

10) Fire Fighting Installations As per Occupancy NOC :

Fire Fighting System.	Required As per Occupancy NOC	Provided
Fire Extinguishers	10	21

11). The Non Multi storeyed Building Inspection Committee have reported that the Management has provided the Fire Safety Measures and there is no deficiencies.

12. Remarks :

As per the recommendation of the Inspection Committee in Sl. No.6, the issuance of Renewal of NOC for Occupancy is approved.

13) In view of the above and as per recommendations of the Non Multi storeyed building inspection Committee, the Renewal of No Objection Certificate for occupancy is issued to Non Multi storeyed Building with **Block H,CBIT/-Kokapet/Gandipet/Rangareddy** with a height of 4.57 Meters for **EDUCATIONAL B-2 All others/training institutions** Occupancy subject to the following conditions

Sl No	Builder and Management Body	Occupant	Management Body and fire and security personnel
1	-a) All the fire protection arrangements shall be maintained in good condition as seen during inspection. -b) Do's and Don'ts in case of fire shall be prominently displayed in entire building	All the escape/exit roots shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting systems installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.	All occupants shall be trained to operate the fire safety equipment during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipment during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101.
4	This No objection Certificate for occupancy is valid for Five year from the date of issue of this letter.	Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing doors and windows.

This Renewal of No Objection Certificate for Occupancy is valid for Five years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison - A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.

Yours Sincerely,
District fire officer,
Rangareddy Division.

Copies to:

- i) The Management
- ii) Non Multi storeyed Building Inspection Committee
- iii) Copy submitted to Regional Fire officer
- iv) Copy submitted to DG fire services

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"



**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**



From
The District fire officer,
Rangareddy Division.

To,
Chaitanya Bharathi Institute of Technology,
Kokapet Village,
Gandipet Mandal,
RR District,

Ack. No.382840002021 Dated:22/04/2021



Sir,
Sub: **TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT –Rangareddy Division. Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building of Block K,CBIT/-Kokapet/Gandipet/Rangareddy , – Regarding.**

Ref: 1. Acknowledgement No 382840002021
2. This Office NOC for Occupancy Ack/RC No.2251/A1/2015 dt.22/04/2021
3. Non Multi storeyed Building Inspection Committee Report,
Ack. No. 382840002021, dt. 22/04/2021

- 1) The Non Multi storeyed Building Inspection committee, vide reference cited (3) has inspected the Non Multi storeyed Building of Block K,CBIT/-Kokapet/Gandipet/Rangareddy
- 2) The above said building was issued was issued No Objection certificate vide reference cited (2) for Non Multi storeyed Building with 2 Ground, 3 Floors, with a height of 14.60 Meters for EDUCATIONAL B-2 All others/training institutions Occupancy .
- 3) Now the Builder/Authorized person has requested to issue Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building with 2 Ground, 3 Floors, with a height of 14.60 Meters for EDUCATIONAL B-2 All others/training institutions Occupancy

4) Open Spaces:The builder provided the following open spaces all around the building.

Sl.No	Side	Open spaces as per Noc occupancy	Open spaces provided now
1	North	3.00	10.00
2	South	3.00	10.00
3	East	3.00	10.00
4	West	3.00	15.00
b Sl. No	Gate Width As per Occupancy NOC	as per Noc occupancy	provided now
1	Entry gate width	4.50	4.5
2	Entry Gate Head Clearance	5.00	5
3	Exit Gate Width	4.50	4.5
4	Exit Gate Head Clearance	5.00	5

5) Travel Distance

Sl. No.	Item / Description	as per Noc occupancy	provided now
1	Farthest point (Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	30.00	30.00
2	The Dead end of the corridor length in exit access. (6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	10.00	10.00

6) Stair Cases (As per Occupancy NOC) :

Sl.no.	Type of staircases	Total width	No of staircases	Floors from	Floors to
1	Internal staircases	1.52	1	Ground	Terrace

2	Internal staircases	1.58	1	Ground	Terrace
---	---------------------	------	---	--------	---------

7) Means of Escape Floor Wise Details :

Sl.no	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy	Occupant Load	Means of escape required as per Occupancy NOC	Means escape available now
1	Lower Ground	245.63	EDUCATIONAL B-2 All others/training institutions	61.00	2.77	2.77
2	Ground	964.68	EDUCATIONAL B-2 All others/training institutions	241.00	2.77	2.77
3	1st Floor	964.68	EDUCATIONAL B-2 All others/training institutions	241.00	2.77	2.77
4	2nd Floor	964.68	EDUCATIONAL B-2 All others/training institutions	241.00	2.77	2.77
5	3rd Floor	964.68	EDUCATIONAL B-2 All others/training institutions	241.00	2.77	2.77

8) Fire Shaft as per Occupancy NOC:

9) Floor Wise details of Fire Fighting Installations:

Sl.n	Floor Details	Fire Extinguisher	Hose Reel	Automatic Sprinklers System	Manually Operated Electronic Fire Alarm System	Automatic detection and alarm system
1	Lower Ground	2.00	1.00	0.00	0.00	0.00
2	Ground	5.00	1.00	0.00	0.00	0.00
3	1st Floor	5.00	1.00	0.00	0.00	0.00
4	2nd Floor	5.00	1.00	0.00	0.00	0.00
5	3rd Floor	5.00	1.00	0.00	0.00	0.00

10) Fire Fighting Installations As per Occupancy NOC :

Fire Fighting System.	Required As per Occupancy NOC	Provided
Fire Extinguishers	32	32
First Aid Hose Reel	9	9
Down Comer	1	1
Terrace Tank over Respective Tower Terrace in Litres	25000	25000
Pump Capacity in LPM at the Terrace Tank Level with Minimum Pressure of 3.5 kg/cm ²	450	450
Number of Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm ² at Remotest Location (Electrical)	1	1
Capacity of Electrical Pump in LPM	450	450

11). The Non Multi storeyed Building Inspection Committee have reported that the Management has provided the Fire Safety Measures and there is no deficiencies.

12. Remarks :

As per the recommendation of the Inspection Committee in Sl. No.6, the issuance of Renewal of NOC for Occupancy is approved.

13) In view of the above and as per recommendations of the Non Multi storeyed building inspection Committee, the Renewal of No Objection Certificate for occupancy is issued to Non Multi storeyed Building with **Block K,CBIT/-Kokapet/Gandipet/Rangareddy** with a height of 14.60 Meters for **EDUCATIONAL B-2 All others/training institutions** Occupancy subject to the following conditions

Sl	Builder and Management Body	Occupant	Management Body and fire and security personnel
1	-a) All the fire protection arrangements shall be maintained	All the escape/exit routes shall not be kept locked/blocked or	All the occupants must know the correct method of operation of the fire fighting

	in good condition as seen during inspection. -b) Do's and Don'ts in case of fire shall be prominently displayed in entire building	encroached	systems installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.	All occupants shall be trained to operate the fire safety equipment during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipment during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101.
4	This No objection Certificate for occupancy is valid for Five year from the date of issue of this letter.	Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing doors and windows.

This Renewal of No Objection Certificate for Occupancy is valid for Five years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison – A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.

Yours Sincerely,
District fire officer,
Rangareddy Division.

Copies to:

- i) The Management
- ii) Non Multi storeyed Building Inspection Committee
- iii) Copy submitted to Regional Fire officer
- iv) Copy submitted to DG fire services

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"



**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**



From
The District fire officer,
Rangareddy Division.

To,
Chaitanya Bharathi Institute of Technology,
Kokapet Village,
Gandipet Mandal,
Ranga Reddy Districtg.

Ack. No. **382880002021** Dated: **16/04/2021**

Sir,
Sub:

TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT –Rangareddy Division. Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building of **Block L,CBIT/-Kokapet/Gandipet/Rangareddy** , – Regarding.



Ref:

1. Acknowledgement No **382880002021**
2. This Office NOC for Occupancy Ack/RC No. **2251/A1/2015** dt. **16/04/2021**
3. Non Multi storeyed Building Inspection Committee Report.,
Ack. No. **382880002021**, dt. **16/04/2021**

***** ***** *****

- 1) The Non Multi storeyed Building Inspection committee, vide reference cited (3) has inspected the Non Multi storeyed Building of **Block L,CBIT/-Kokapet/Gandipet/Rangareddy**
- 2) The above said building was issued was issued No Objection certificate vide reference cited (2) for Non Multi storeyed Building with **1 Ground, 3 Floors**, with a height of **14.60** Meters for **EDUCATIONAL B-2 All others/training institutions** Occupancy .
- 3) Now the Builder/Authorized person has requested to issue Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building with **1 Ground, 3 Floors**, with a height of **14.60** Meters for **EDUCATIONAL B-2 All others/training institutions** Occupancy

4) Open Spaces: The builder provided the following open spaces all around the building.

Sl.No	Side	Open spaces as per Noc occupancy	Open spaces provided now
a.1	North	3.00	17.09
2	South	3.00	17.74
3	East	3.00	15.85
4	West	3.00	15.00
b. Sl. No	Gate Width As per Occupancy NOC	as per Noc occupancy	provided now
1	Entry gate width	4.50	4.5
2	Entry Gate Head Clearance	5.00	5
3	Exit Gate Width	4.50	4.5
4	Exit Gate Head Clearance	5.00	5

5) Travel Distance

Sl. No.	Item / Description	as per Noc occupancy	provided now
1	Farthest point (Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	30.00	25.00
2	The Dead end of the corridor length in exit access. (6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	6.00	6.00

6) Stair Cases (As per Occupancy NOC) :

Sl.no.	Type of staircases	Total width	No of staircases	Floors from	Floors to
1	Internal staircases	1.70	1	Ground	3rd Floor

2 External staircases 1.70 1 Ground 3rd Floor

7) Means of Escape Floor Wise Details :

Sl.no	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy	Occupant Load	Means of escape required as per Occupancy NOC	Means escape available now
1	Ground	990.38	EDUCATIONAL B-2 All others/training institutions	160.00	3.20	8.00
2	1st Floor	990.38	EDUCATIONAL B-2 All others/training institutions	160.00	3.20	3.40
3	2nd Floor	990.38	EDUCATIONAL B-2 All others/training institutions	160.00	3.20	3.40
4	3rd Floor	990.38	EDUCATIONAL B-2 All others/training institutions	160.00	3.20	3.40

8) Fire Shaft as per Occupancy NOC:

9) Floor Wise details of Fire Fighting Installations:

Sl.no	Floor Details	Fire Extinguisher	Hose Reel	Automatic Sprinklers System	Manually Operated Fire Alarm System	Electronic Fire Alarm System	Automatic detection and alarm system
1	Ground	10.00	2.00	0.00	0.00	0.00	0.00
2	1st Floor	10.00	2.00	0.00	0.00	0.00	0.00
3	2nd Floor	10.00	2.00	0.00	0.00	0.00	0.00
4	3rd Floor	10.00	2.00	0.00	0.00	0.00	0.00

10) Fire Fighting Installations As per Occupancy NOC :

Fire Fighting System.	Required As per Occupancy NOC	Provided
Fire Extinguishers	40	40
First Aid Hose Reel	8	8
Terrace Tank over Respective Tower Terrace in Litres	10000	25000
Pump Capacity in LPM at the Terrace Tank Level with Minimum Pressure of 3.5 kg/cm ²	450	450

11). The Non Multi storeyed Building Inspection Committee have reported that the Management has provided the Fire Safety Measures and there is no deficiencies.

12. Remarks :

As per the recommendation of the Inspection Committee in Sl. No.5, the issuance of Renewal of NOC for Occupancy is approved.

13) In view of the above and as per recommendations of the Non Multi storeyed building inspection Committee, the Renewal of No Objection Certificate for occupancy is issued to Non Multi storeyed Building with **Block L,CBIT/-Kokapet/Gandipet/Rangareddy** with a height of **14.60** Meters for **EDUCATIONAL B-2 All others/training institutions** Occupancy subject to the following conditions

Sl No	Builder and Management Body	Occupant	Management Body and fire and security personnel
1	-a) All the fire protection arrangements shall be maintained in good condition as seen during inspection. -b) Do's and Don'ts in case of fire shall be prominently displayed in entire building	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting systems installed.

2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.	All occupants shall be trained to operate the fire safety equipment during emergency. Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months. All security personnel shall be trained to operate the fire safety equipment during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101.
4	This No objection Certificate for occupancy is valid for Five year from the date of issue of this letter.	Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit. Attack the fire using available fire equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing doors and windows.

This Renewal of No Objection Certificate for Occupancy is valid for Five years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison - A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.

Yours Sincerely,
District fire officer,
Rangareddy Division.

Copies to:

- i) The Management
- ii) Non Multi storeyed Building Inspection Committee
- iii) Copy submitted to Regional Fire officer
- iv) Copy submitted to DG fire services

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"



**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**



From
The District fire officer,
Rangareddy Division.

To,
Chaitanya Bharathi Institute of Technology,
Kokapet Village,
Gandipet Mandal,
Ranga Reddy District,

Ack. No.382900002021 Dated:25/04/2021



Sir,
Sub: **TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT –Rangareddy Division. Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building of Block M,CBIT/-Kokapet/Gandipet/Rangareddy , – Regarding.**

Ref: 1. Acknowledgement No 382900002021
2. This Office NOC for Occupancy Ack/RC No.2251/A1/2015 dt.25/04/2021
3. Non Multi storeyed Building Inspection Committee Report.,
Ack. No. 382900002021, dt. 25/04/2021

- 1) The Non Multi storeyed Building Inspection committee, vide reference cited (3) has inspected the Non Multi storeyed Building of **Block M,CBIT/-Kokapet/Gandipet/Rangareddy**
- 2) The above said building was issued was issued No Objection certificate vide reference cited (2) for Non Multi storeyed Building with **1 Ground, 3 Floors, 1 Terrace** with a height of **14.60** Meters for **EDUCATIONAL B-2 All others/training institutions** Occupancy .
- 3) Now the Builder/Authorized person has requested to issue Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building with **1 Ground, 3 Floors, 1 Terrace** with a height of **14.60** Meters for **EDUCATIONAL B-2 All others/training institutions** Occupancy

4) Open Spaces:The builder provided the following open spaces all around the building.

Sl.No	Side	Open spaces as per Noc occupancy	Open spaces provided now
a 1	North	3.00	15.00
2	South	3.00	6.00
3	East	3.00	14.25
4	West	3.00	15.00
b	Sl. No	Gate Width As per Occupancy NOC	as per Noc occupancy
1	Entry gate width	6.00	6
2	Entry Gate Head Clearance	5.00	5
3	Exit Gate Width	6.00	6
4	Exit Gate Head Clearance	5.00	5.00

5) Travel Distance

Sl. No.	Item / Description	as per Noc occupancy	provided now
1	Farthest point (Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	29.00	29.00
2	The Dead end of the corridor length in exit access. (6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	5.00	5.00

6) Stair Cases (As per Occupancy NOC) :

Sl.no.	Type of staircases	Total width	No of staircases	Floors from	Floors to
1	Internal staircases	1.68	1	Ground	3rd Floor

2	External staircases	1.68	1	Ground	3rd Floor
---	---------------------	------	---	--------	-----------

7) Means of Escape Floor Wise Details :

Sl.no	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy	Occupant Load	Means of escape required as per Occupancy NOC	Means escape available now
1	Ground	999.72	EDUCATIONAL B-2 All others/training institutions	160.00	5.00	5.00
2	1st Floor	999.72	EDUCATIONAL B-2 All others/training institutions	160.00	3.20	3.36
3	2nd Floor	999.72	EDUCATIONAL B-2 All others/training institutions	160.00	3.20	3.36
4	3rd Floor	999.72	EDUCATIONAL B-2 All others/training institutions	160.00	3.20	3.36
5	Terrace	84.62	EDUCATIONAL B-2 All others/training institutions	0.00	1.50	3.36

8) Fire Shaft as per Occupancy NOC:

9) Floor Wise details of Fire Fighting Installations:

Sl.No	Floor Details	Fire Extinguisher	Hose Reel	Automatic Sprinklers System	Manually Operated Fire Alarm System	Electronic Alarm System	Automatic detection and alarm system
1	Ground	10.00	2.00	0.00	0.00		0.00
	1st Floor	10.00	2.00	0.00	0.00		0.00
3	2nd Floor	10.00	2.00	0.00	0.00		0.00
4	3rd Floor	10.00	2.00	0.00	0.00		0.00
5	Terrace	0.00	0.00	0.00	0.00		0.00

10) Fire Fighting Installations As per Occupancy NOC :

Fire Fighting System.	Required As per Occupancy NOC	Provided
Fire Extinguishers	40	40
First Aid Hose Reel	8	8
Terrace Tank over Respective Tower Terrace in Litres	25000	25000
Pump Capacity in LPM at the Terrace Tank Level with Minimum Pressure of 3.5 kg/cm ²	450	450

11). The Non Multi storeyed Building Inspection Committee have reported that the Management has provided the Fire Safety Measures and there is no deficiencies.

12. Remarks :

As per the recommendation of the Inspection Committee in Sl. No.5, the issuance of Renewal of NOC for Occupancy is approved.

(13) In view of the above and as per recommendations of the Non Multi storeyed building inspection Committee, the Renewal of No Objection Certificate for occupancy is issued to Non Multi storeyed Building with Block M,CBIT/-Kokapet/Gandipet/Rangareddy with a height of 14.60 Meters for EDUCATIONAL B-2 All others/training institutions Occupancy subject to the following conditions

Sl No	Builder and Management Body	Occupant	Management Body and fire and security personnel
1	-a) All the fire protection arrangements shall be maintained in good condition as seen during inspection. -b) Do's and Don'ts in case of fire	All the escape/exit roots shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting systems installed.

	shall be prominently displayed in entire building		
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.	All occupants shall be trained to operate the fire safety equipment during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipment during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101.
4	This No objection Certificate for occupancy is valid for Five year from the date of issue of this letter.	Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing doors and windows.

This Renewal of No Objection Certificate for Occupancy is valid for Five years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison – A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.

Yours Sincerely,
District fire officer,
Rangareddy Division.

Copies to:

- i) The Management
- ii) Non Multi storeyed Building Inspection Committee
- iii) Copy submitted to Regional Fire officer
- iv) Copy submitted to DG fire services

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"



**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**



From
The District fire officer,
Rangareddy Division.

To,
Chaitanya Bharathi Institute of Technology,
Kokapet Village,
Gandipet Mandal,
Ranga Reddy District,

Ack. No.382910002021 Dated:22/04/2021



Sir,
Sub: **TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT –Rangareddy Division. Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building of Block N,CBIT/-Kokapet/Gandipet/Rangareddy , – Regarding.**

Ref: 1. Acknowledgement No 382910002021
2. This Office NOC for Occupancy Ack/RC No.2251/A1/2015 dt.22/04/2021
3. Non Multi storeyed Building Inspection Committee Report, Ack. No. 382910002021, dt. 22/04/2021

- 1) The Non Multi storeyed Building Inspection committee, vide reference cited (3) has inspected the Non Multi storeyed Building of Block N,CBIT/-Kokapet/Gandipet/Rangareddy
- 2) The above said building was issued was issued No Objection certificate vide reference cited (2) for Non Multi storeyed Building with **2 Ground, 3 Floors, 1 Terrace** with a height of **14.89 Meters** for **EDUCATIONAL B-2 All others/training institutions** Occupancy .
- 3) Now the Builder/Authorized person has requested to issue Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building with **2 Ground, 3 Floors, 1 Terrace** with a height of **14.89 Meters** for **EDUCATIONAL B-2 All others/training institutions** Occupancy

4) Open Spaces:The builder provided the following open spaces all around the building.

Sl.No	Side	Open spaces as per Noc occupancy	Open spaces provided now
a. 1	North	3.00	17.09
2	South	3.00	17.55
3	East	3.00	10.00
4	West	3.00	15.00
b. Sl. No	Gate Width As per Occupancy NOC	as per Noc occupancy	provided now
1	Entry gate width	4.50	4.5
2	Entry Gate Head Clearance	5.00	5
3	Exit Gate Width	4.50	4.5
4	Exit Gate Head Clearance	5.00	5

5) Travel Distance

Sl. No.	Item / Description	as per Noc occupancy	provided now
1	Farthest point (Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	10.00	10.00
2	The Dead end of the corridor length in exit access. (6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	0.00	0.00

6) Stair Cases (As per Occupancy NOC) :

Sl.no.	Type of staircases	Total width	No of staircases	Floors from	Floors to
1	Internal staircases	1.80	1	Ground	Terrace

2	External staircases	1.70	1	Ground	Terrace
---	---------------------	------	---	--------	---------

7) Means of Escape Floor Wise Details :

Sl.no	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy	Occupant Load	Means of escape required as per Occupancy NOC	Means escape available now
1	Lower Ground	316.54	EDUCATIONAL B-2 All others/training institutions	79.00	1.58	3.50
2	Ground	1008.36	EDUCATIONAL B-2 All others/training institutions	252.00	3.50	3.50
3	1st Floor	1008.36	EDUCATIONAL B-2 All others/training institutions	252.00	3.50	3.50
4	2nd Floor	1008.36	EDUCATIONAL B-2 All others/training institutions	252.00	3.50	3.50
5	3rd Floor	1008.36	EDUCATIONAL B-2 All others/training institutions	252.00	3.50	3.50
6	Terrace	120.72	EDUCATIONAL B-2 All others/training institutions	30.00	3.50	3.50

8) Fire Shaft as per Occupancy NOC:

9) Floor Wise details of Fire Fighting Installations:

Sl.n	Floor Details	Fire Extinguisher	Hose Reel	Automatic Sprinklers System	Manually Operated Electronic Fire Alarm System	Automatic detection and alarm system
1	Lower Ground	2.00	1.00	0.00	0.00	0.00
2	Ground	6.00	2.00	0.00	0.00	0.00
3	1st Floor	6.00	2.00	0.00	0.00	0.00
4	2nd Floor	6.00	2.00	0.00	0.00	0.00
5	3rd Floor	6.00	2.00	0.00	0.00	0.00
6	Terrace	0.00	0.00	0.00	0.00	0.00

10) Fire Fighting Installations As per Occupancy NOC :

Fire Fighting System.	Required As per Occupancy NOC	Provided
Fire Extinguishers	44	44
First Aid Hose Reel	9	9
Down Comer	1	1
Terrace Tank over Respective Tower Terrace in Litres	25000	2500
Pump Capacity in LPM at the Terrace Tank Level with Minimum Pressure of 3.5 kg/cm ²	450	450

11). The Non Multi storeyed Building Inspection Committee have reported that the Management has provided the Fire Safety Measures and there is no deficiencies.

12. Remarks :

As per the recommendation of the Inspection Committee in Sl. No.6, the issuance of Renewal of NOC for Occupancy is approved.

13) In view of the above and as per recommendations of the Non Multi storeyed building inspection Committee, the Renewal of No Objection Certificate for occupancy is issued to Non Multi storeyed Building with **Block N,CBIT/-Kokapet/Gandipet/Rangareddy** with a height of **14.89** Meters for **EDUCATIONAL B-2 All others/training institutions** Occupancy subject to the following conditions

Sl No	Builder and Management Body	Occupant	Management Body and fire and security personnel
1	-a) All the fire protection arrangements shall be maintained	All the escape/exit routes shall not be kept locked/blocked or	All the occupants must know the correct method of operation of the fire fighting

	in good condition as seen during inspection. -b) Do's and Don'ts in case of fire shall be prominently displayed in entire building	encroached	systems installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.	All occupants shall be trained to operate the fire safety equipment during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipment during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101.
4	This No objection Certificate for occupancy is valid for Five year from the date of issue of this letter.	Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing doors and windows.

This Renewal of No Objection Certificate for Occupancy is valid for Five years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison - A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.

Yours Sincerely,
District fire officer,
Rangareddy Division.

- Copies to:
- i) The Management
 - ii) Non Multi storeyed Building Inspection Committee
 - iii) Copy submitted to Regional Fire officer
 - iv) Copy submitted to DG fire services

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"



GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT



From
The District fire officer,

Rangareddy Division.

To,
Chaitanya Bharathi Institute of Technology,
Kokapet Village,
Gandipet Mandal,
Ranga Reddy District,

Ack. No.383220002021 Dated:18/04/2021

Sir,
Sub: TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE
DEPARTMENT –Rangareddy Division. Renewal of No Objection
Certificate for Occupancy to the Non Multi storeyed Building of
Information Centre & Library Block,CBIT/-
Kokapet/Gandipet/Rangareddy , – Regarding.



Ref: 1. Acknowledgement No 383220002021
2. This Office NOC for Occupancy Ack/RC No.2251/A1/2015 dt.18/04/2021
3. Non Multi storeyed Building Inspection Committee Report.,
Ack. No. 383220002021, dt. 18/04/2021

- 1) The Non Multi storeyed Building Inspection committee, vide reference cited (3) has inspected the Non Multi storeyed Building of Information Centre & Library Block,CBIT/-Kokapet/Gandipet/Rangareddy
- 2) The above said building was issued was issued No Objection certificate vide reference cited (2) for Non Multi storeyed Building with 1 Ground, 2 Floors, with a height of 12.92 Meters for EDUCATIONAL B-2 All others/training institutions Occupancy .
- 3) Now the Builder/Authorized person has requested to issue Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building with 1 Ground, 2 Floors, with a height of 12.92 Meters for EDUCATIONAL B-2 All others/training institutions Occupancy

4) Open Spaces:The builder provided the following open spaces all around the building.

Sl.No	Side	Open spaces as per Noc occupancy	Open spaces provided now
a. 1	North	3.00	20.00
2	South	3.00	7.50
3	East	3.00	17.15
4	West	3.00	7.25
b. Sl. No	Gate Width As per Occupancy NOC	as per Noc occupancy	provided now
1	Entry gate width	4.50	4.5
2	Entry Gate Head Clearance	5.00	5
3	Exit Gate Width	4.50	4.5
4	Exit Gate Head Clearance	5.00	5

5) Travel Distance

Sl. No.	Item / Description	as per Noc occupancy	provided now
1	Farthest point (Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	30.00	25.00
2	The Dead end of the corridor length in exit access. (6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	6.00	6.00

6) Stair Cases (As per Occupancy NOC) :

Sl.no.	Type of staircases	Total width	No of staircases	Floors from	Floors to
--------	--------------------	-------------	------------------	-------------	-----------

1	Internal staircases	1.20	2	Ground	1st Floor
2	External staircases	1.70	1	Ground	2nd Floor

7) Means of Escape Floor Wise Details :

Sl.no	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy	Occupant Load	Means of escape required as per Occupancy NOC	Means escape available now
1	Ground	1025.00	EDUCATIONAL B-2 All others/training institutions	103.00	2.06	6.00
2	1st Floor	687.36	EDUCATIONAL B-2 All others/training institutions	69.00	1.38	4.10
3	2nd Floor	687.38	EDUCATIONAL B-2 All others/training institutions	69.00	1.38	1.70

8) Fire Shaft as per Occupancy NOC:

9) Floor Wise details of Fire Fighting Installations:

Sl.no	Floor Details	Fire Extinguisher	Hose Reel	Automatic Sprinklers System	Manually Operated Fire Alarm System	Electronic Alarm System	Automatic detection and alarm system
1	Ground	11.00	1.00	0.00	0.00	0.00	0.00
2	1st Floor	7.00	1.00	0.00	0.00	0.00	0.00
3	2nd Floor	7.00	1.00	0.00	0.00	0.00	0.00

10) Fire Fighting Installations As per Occupancy NOC :

Fire Fighting System.	Required As per Occupancy NOC	Provided
Fire Extinguishers	25	25
First Aid Hose Reel	3	3
Terrace Tank over Respective Tower Terrace in Litres	10000	25000
Pump Capacity in LPM at the Terrace Tank Level with Minimum Pressure of 3.5 kg/cm ²	450	450

11). The Non Multi storeyed Building Inspection Committee have reported that the Management has provided the Fire Safety Measures and there is no deficiencies.

12. Remarks :

As per the recommendation of the Inspection Committee in Sl. No.4 &6, the issuance of Renewal of NOC for occupancy is approved.

13) In view of the above and as per recommendations of the Non Multi storeyed building inspection Committee, the Renewal of No Objection Certificate for occupancy is issued to Non Multi storeyed Building with **Information Centre & Library Block, CBIT/-Kokapet/Gandipet/Rangareddy** with a height of 12.92 Meters for **EDUCATIONAL B-2 All others/training institutions** Occupancy subject to the following conditions

Sl No	Builder and Management Body	Occupant	Management Body and fire and security personnel
1	-a) All the fire protection arrangements shall be maintained in good condition as seen during inspection. -b) Do's and Don'ts in case of fire shall be prominently displayed in entire building	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting systems installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall	All occupants shall be trained to operate the fire safety equipment during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.

	be the responsibility of the management.	
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
4	This No objection Certificate for occupancy is valid for Five year from the date of issue of this letter.	Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit.
		All security personnel shall be trained to operate the fire safety equipment during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101. Attack the fire using available fire equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing doors and windows.


This Renewal of No Objection Certificate for Occupancy is valid for Five years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison – A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.

Yours Sincerely,
District fire officer,
Rangareddy Division.

Copies to:

- i) The Management
- ii) Non Multi storeyed Building Inspection Committee
- iii) Copy submitted to Regional Fire officer
- iv) Copy submitted to DG fire services

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"



GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT



From
The District fire officer,
Rangareddy Division.

To,
Chaitanya Bharathi Institute of Technology,
Kokapet Village,
Gandipet Mandal,
Ranga Reddy District,

Ack. No.383110002021 Dated:16/04/2021

Sir,
Sub:

TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE
DEPARTMENT –Rangareddy Division. Renewal of No Objection
Certificate for Occupancy to the Non Multi storeyed Building of
Indoor Sports & Shuttle Badminton Block,CBIT/-
Kokapet/Gandipet/Rangareddy , – Regarding.



Ref: 1. Acknowledgement No **383110002021**
2. This Office NOC for Occupancy Ack/RC No.2251/A1/2015 dt.16/04/2021
3. Non Multi storeyed Building Inspection Committee Report,
Ack. No. **383110002021**, dt. **16/04/2021**

- 1) The Non Multi storeyed Building Inspection committee, vide reference cited (3) has inspected the Non Multi storeyed Building of **Indoor Sports & Shuttle Badminton Block,CBIT/-Kokapet/Gandipet/Rangareddy**
- 2) The above said building was issued was issued No Objection certificate vide reference cited (2) for Non Multi storeyed Building with **1 Ground, 3 Floors**, with a height of **14.60 Meters** for **ASSEMBLY D-3 any building, its lobbies, rooms and other spaces connected thereto, primarily intended for assembly of people, but which has no theatrical stage or permanent theatrical and/or cinematographic accessories and has accommodation for 300 persons or more, for Occupancy .**
- 3) Now the Builder/Authorized person has requested to issue Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building with **1 Ground, 3 Floors**, with a height of **14.60 Meters** for **ASSEMBLY D-3 any building, its lobbies, rooms and other spaces connected thereto, primarily intended for assembly of people, but which has no theatrical stage or permanent theatrical and/or cinematographic accessories and has accommodation for 300 persons or more, for Occupancy**

4) Open Spaces:The builder provided the following open spaces all around the building.

Sl.No	Side	Open spaces as per Noc occupancy	Open spaces provided now
a 1	North	3.00	6.50
2	South	3.00	16.55
3	East	3.00	30.24
4	West	3.00	5.33
b Sl. No	Gate Width As per Occupancy NOC	as per Noc occupancy	provided now
1	Entry gate width	4.50	4.5
2	Entry Gate Head Clearance	5.00	5
3	Exit Gate Width	4.50	4.5
4	Exit Gate Head Clearance	5.00	5

5) Travel Distance

Sl. No.	Item / Description	as per Noc occupancy	provided now
1	Farthest point (Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	30.00	29.00
2	The Dead end of the corridor length in exit access. (6 mtrs for Educational,	6.00	6.00

Institutional and Assembly, 15mtrs for other Occupancies)

6) Stair Cases (As per Occupancy NOC) :

Sl.no.	Type of staircases	Total width	No of staircases	Floors from	Floors to
1	Internal staircases	1.89	1	Ground	3rd Floor

7) Means of Escape Floor Wise Details :

Sl.no.	Floor type	Built-up Area in Sq.Mtrs	Type of Occupancy	Occupant Load	Means of escape required as per Occupancy NOC	Means escape available now
1	Ground	1019.45	ASSEMBLY D-3 any building, its lobbies, rooms and other spaces connected thereto, primarily intended for assembly of people, but which has no theatrical stage or permanent theatrical and/or cinematographic accessories and has accommodation for 300 persons or more, for	80.00	0.67	4.00
2	1st Floor	578.83	ASSEMBLY D-3 any building, its lobbies, rooms and other spaces connected thereto, primarily intended for assembly of people, but which has no theatrical stage or permanent theatrical and/or cinematographic accessories and has accommodation for 300 persons or more, for	80.00	1.00	1.89
3	2nd Floor	578.83	ASSEMBLY D-3 any building, its lobbies, rooms and other spaces connected thereto, primarily intended for assembly of people, but which has no theatrical stage or permanent theatrical and/or cinematographic accessories and has accommodation for 300 persons or more, for	80.00	1.00	1.89
4	3rd Floor	578.83	ASSEMBLY D-3 any building, its lobbies, rooms and other spaces connected thereto, primarily intended for assembly of people, but which has no theatrical stage or permanent theatrical and/or cinematographic accessories and has accommodation for 300 persons or more, for	80.00	1.00	1.89

8) Fire Shaft as per Occupancy NOC:

9) Floor Wise details of Fire Fighting Installations:

Sl.no	Floor Details	Fire Extinguisher	Hose Reel	Automatic Sprinklers System	Manually Operated Fire Alarm System	Electronic Fire Alarm System	Automatic detection and alarm system
1	Ground	10.00	1.00	0.00	0.00	0.00	0.00
2	1st Floor	6.00	1.00	0.00	0.00	0.00	0.00
3	2nd Floor	6.00	1.00	0.00	0.00	0.00	0.00
4	3rd Floor	6.00	1.00	0.00	0.00	0.00	0.00

10) Fire Fighting Installations As per Occupancy NOC :

Fire Fighting System.	Required As per Occupancy NOC	Provided
Fire Extinguishers	28	28
First Aid Hose Reel	4	4
Terrace Tank over Respective Tower Terrace in Litres	10000	25000
Pump Capacity in LPM at the Terrace Tank Level with Minimum Pressure of 3.5 kg/cm ²	450	450

11). The Non Multi storeyed Building Inspection Committee have reported that the Management has provided the Fire Safety Measures and there are no deficiencies.

12. Remarks :

As per the recommendation of the Inspection Committee in Sl. No.6, the issuance of Renewal of NOC for Occupancy is approved.

13) In view of the above and as per recommendations of the Non Multi storeyed building inspection Committee, the Renewal of No Objection Certificate for occupancy is issued to Non Multi storeyed Building with **Indoor Sports & Shuttle Badminton Block, CBIT/-Kokapet/Gandipet/Rangareddy** with a height of 14.60 Meters for **ASSEMBLY D-3 any building, its lobbies, rooms and other spaces connected thereto, primarily intended for assembly of people, but which has no theatrical stage or permanent theatrical and/or cinematographic accessories and has accommodation for 300 persons or more, for Occupancy** subject to the following conditions

Sl No	Builder and Management Body	Occupant	Management Body and fire and security personnel
1	-a) All the fire protection arrangements shall be maintained in good condition as seen during inspection. -b) Do's and Don'ts in case of fire shall be prominently displayed in entire building	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting systems installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.	All occupants shall be trained to operate the fire safety equipment during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipment during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101.
4	This No objection Certificate for occupancy is valid for Five year from the date of issue of this letter.	Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing doors and windows.

This Renewal of No Objection Certificate for Occupancy is valid for Five years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison – A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.

Yours Sincerely,
District fire officer,
Rangareddy Division.

Copies to:

- i) The Management
- ii) Non Multi storeyed Building Inspection Committee
- iii) Copy submitted to Regional Fire officer
- iv) Copy submitted to DG fire services

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"